

**Regional Water Testing Laboratory**  
**Water Supply and sanitation, Amritsar**

ID No. **RWTLASR/1391**

Dated **11/08/2021**

**TEST REPORT**  
**Chemical Testing**


Sr. No	Group	Sample Tested in Group (√)
1.	Residues in Water	
2.	Water	

Sample Registration No. : **RWTLASR/1391**  
Sample code given by customer: **Not Applicable**

Issued to: -The Principal : **Shaheed Bhagat Singh**  
**International School Tarn Taran Road ,Varpal ASR**

**SAMPLE PARTICULARS**

Ref. Letter No. : **SBSIS/D/2021-22/77 Dated 27-7-2021**  
Date of Receipt : **29/07/2021**  
Sample code given by customer : **NA**  
Name / Nature of sample : **water**  
Condition of the sample : **Un-Sealed Sample**  
Qty/Pkg : **750ml plasticBottle**  
Sampling Method : **Sample not drawn by RWTLASR**  
Test Start Date : **30/07/2021**  
Test Completion Date : **30/07/2021**

  
**Senior Chemist**  
**Authorised Signatory**  
**For Regional Water Testing Laboratory,**  
**Quality Manager/ Sr. Chemist**

**Note:**

- ☞ The enclosed results pertain only to the sample tested.
- ☞ The report shall not be used for advertising or any legal purpose without written permission from the Head, DWSS.
- ☞ This report cannot be re-produced, except when in full, without the written permission from the Head, DWSS.
- ☞ The sample shall be destroyed after one month from the date of issue of the report.

## Regional Water Testing Laboratory, Amritsar

Date 11/08/2021

S No	Registration No	District	Block	Name of Place/Village	Sample Receipt Date	Date of Collection	Source	Depth	pH	TDS (mg/l)	Total Alkalinity (mg/l)	Total Hardness (mg/l)	Turbidity	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Odour	Taste	Colour
As per IS 3025:2017 : Requirement (Acceptable limit - Permissible limit) mg/L																			
1	RWTLASR/191	Amritsar	NA	The Principal Shaheed Bhagat Singh International School , Varpal ASR	29-07-2021	27-07-2021	S/P	400 Ft	7.75	230	304	164	0.21	48.0	10.5	7.9	Agreeable	Agreeable	0.5 Hazen

Quality Manager/Sr. Chemist

  
**Senior Chemist**  
**Authorised Signatory**  
**For Regional Water Testing Laboratory,**  
**Amritsar**

End of Report